

HMW-19

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 77683

Permit No. _____

Basin. 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9684

1. OWNER HAYCOCK PETROLEUM Co ADDRESS AT WELL LOCATION 715 W. BONANZA Rd.
 MAILING ADDRESS 715 W. BONANZA Rd. LAS VEGAS NV. 89106 LAS VEGAS NV. 89106

2. LOCATION NW 1/4 SW 1/4 Sec. 27 T. 20 N. R. 61 E. CLARK County
 PERMIT NO. 139-27-901-001 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other H.S.A. CME 15

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
- CONCRETE, 8 inches thick				
- BROWN SILTY CLAY		0'	4'	4'
- GRAY SILTY CLAY HYDROCARBON ORDER		4'	8'	4'
- GRAY CLAYEY SILT		8'	14'	6'
- CALICHE		14'	15'	1'
- END OF BOREHOLE @ 15'				

8. WELL CONSTRUCTION

Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>8</u> Inches	<u>0</u> Feet <u>15</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>.203</u>	<u>.237</u>	<u>0</u>	<u>15</u>

Perforations:
 Type perforation _____
 Size perforation .020 INCHES
 From 5 feet to 15 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 3' feet to 15' feet

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

Date started 10-30-99, 19_____
 Date completed 10-30-99, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>N/A</u>	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (THOMAS SPILOTO) WEST HAZMAT DRILLING Contractor
 Address 1016 E. HATELLA AVE Contractor
ANALHEIM CA 92805

Nevada contractor's license number issued by the State Contractor's Board 0031386

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2627

Signed Thomas Spiloto
 By driller performing actual drilling on site or contractor

Date 11-28-99