WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77120
Permit No.
Basin 212

NOTICE OF INTENT NO. 19166

1. OWNER Pauls Corp
MAILING ADDRESS 3950 N. Lewiston St. #100 Aurora, CO 80011
ADDRESS AT WELL LOCATION SWC Lewis Ave. + 4th St.

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. NA (Issued by Water Resources) | 139-34-301-002 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG B-16

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill- Silty Sand + Gravel | | 0 | 2 | |
| SANDY CLAY | | 2 | 3 | |
| SILTY CLAY | | 3 | 7 | |
| SANDY CLAY | | 7 | 8 | |
| SILTY SAND | | 8 | 9.5 | |
| SANDY CLAY | Y | 9.5 | 10.5 | |
| CLAYEY SAND | Y | 10.5 | 12 | |
| SANDY CLAY w/ gravel | Y | 12 | 14 | |
| CALICHE | Y | 14 | 16.5 | |
| SANDY CLAY | Y | 16.5 | 18 | |
| CALICHE | Y | 18 | 19 | |
| SANDY CLAY w/ gravel | Y | 19 | 25 | |

DCNR/DWR Received DEC 27 1999 LAS VEGAS OFFICE

Date started 12/8, 1999
Date completed 12/8, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 23.5 Feet Depth Cased 23.5 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 6 | 0 | 23.5 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | sch 40 | 0 | 23.5 |
| | | | | |
| | | | | |

Perforations:
Type perforation slotted screen
Size perforation .010 inch
From 8.5 feet to 23.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 7 feet to 23.5 feet

9. WATER LEVEL
Static water level 10.16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants Western Inc. (Contractor)
Address 4343 So. Polaris Ave. Las Vegas Nevada 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944
Signed Thomas H. Beall (By driller performing actual drilling on site or contractor)
Date 12-15-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627