

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77724
 Permit No. _____
 Basin 163

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19257

1. OWNER ALAN & SANDRA SLAVIN ADDRESS AT WELL LOCATION POTOMAC + JASPER SANDY VALLEY
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec 26 T 24 N R 56 E Clark County
 PERMIT NO. 580-250-076 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CLAY		6	32	26
CALICHE		32	35	3
CLAY		35	58	23
CALICHE		58	64	6
CLAY		64	83	19
CALICHE	W.B.	83	92	9
CLAY		92	102	10
CALICHE	W.B.	102	128	26
CLAY		128	135	6
CALICHE	W.B.	135	140	5

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
 To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation FACTORY SCREEN
 Size perforation 4 INCH BY 3 INCH
 From 140 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 6.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 11-22, 1999
 Date completed 11-23, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO Contractor
 Address P.O. Box 3505 Contractor
PAHRAMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 40021
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
 Signed Thomas Brown
 By driller performing actual drilling on site or contractor
 Date 11-23-99

