


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. ....  
 Permit No. ....  
 Basin 106



NOTICE OF INTENT NO. 4124

1. OWNER Barbara Stapleton  
 MAILING ADDRESS PO Box 2449 Gardnerville NV 89410  
 ADDRESS AT WELL LOCATION 3230 Concho St Gardnerville NV 89410  
 2. LOCATION SW 1/4 NW 1/4 Sec 18 T 10 S R 22 E Douglas County  
 PERMIT NO. 37-121-30  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Large Broken Volcanic Rock and Brown Clay		0	65	65
Broken Volcanic Rock and Brown Clay		65	185	120
Brown Clay		185	210	25
Broken Volcanic Rock and Brown Clay		210	310	100
Broken Rock and Brown Clay More Rock Than Clay	Y	310	360	50

8. WELL CONSTRUCTION  
 Depth Drilled 360 Feet Depth Cased 360 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/2 Inches 0 Feet 50 Feet  
10 Inches 50 Feet 360 Feet  
 Inches Feet Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1.88</u>	<u>+2</u>	<u>300</u>

 Perforations:  
 Type perforation Mill Slot  
 Size perforation 3/32  
 From 300 feet to 360 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 360 feet

Date started 5-28, 1999  
 Date completed 6-8-99, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIRLIFT</u>	<u>5</u>	<u>Total</u>	<u>5</u>

9. WATER LEVEL  
 Static water level 140 feet below land surface  
 Artesian flow — G.P.M. — P.S.I.  
 Water temperature cold °F Quality —

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NU Drilling Inc. Contractor  
 Address 75 Lowers Cr. Rd Carson City Contractor  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1790  
 Division of Water Resources, the on-site driller  
 Signed NDH  
 By driller performing actual drilling on site or contractor  
 Date 6-10-99