WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77746
Permit No.
Basin 48

NOTICE OF INTENT NO. 41839

1. OWNER GEORGE A. PACINI
MAILING ADDRESS HC 30 353-3
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION NW CORNER OF SECOND ST & DOOLITTLE

2. LOCATION SW 1/4 SE 1/4 Sec. 23 T 32N N/S R 55E E ELKO County
PERMIT NO. Issued by Water Resources | 027-053-008 Parcel No. | LUCKY NUGGET #1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
GRAVEL & BOULDERS		3	24	21
YELLOW CLAY		24	51	27
GREY SILTSTONE		51	165	114
FRACTURED SILTSTONE	X	165	240	75
FINE GRAVEL &	X	240		
SILTSTONE			280	40

RECEIVED 99 JUL 30 AM 11:38 STATE ENGINEER'S OFFICE

Date started 7/6/99, 19__
Date completed 7/7/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
70		2

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	280	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	280

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 111 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC Contractor
Address P.O.BOX 850 Contractor
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed By driller performing actual drilling on-site or contractor
Date 7/9/99

USE ADDITIONAL SHEETS IF NECESSARY