WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77753
Permit No.
Basin 49

NOTICE OF INTENT NO. 41[illegible]5

1. OWNER ADOBE HEIGHTS
MAILING ADDRESS P. O. BOX 7316
INCLINE VILLAGE, NV 89452

ADDRESS AT WELL LOCATION SW CORNER OF MESA DRIVE AND ADOBE HEIGHTS ROAD

2. LOCATION NE 1/4 SW 1/4 Sec. 1 T 34N N/S R 54E E ELKO County
PERMIT NO. (Issued by Water Resources) 5-510-39 (Parcel No.) ADOBE HEIGHTS (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOP SOIL		0	3	3
BROWN CLAY		3	80	77
GRAY CLAY		80	300	220
GRAY CLAY, SOME HARD	X	300		
LAYERS			780	480

RECEIVED
99 JUL -9 AM 11:26
STATE ENGINEER'S OFFICE

Date started 6/30/99 , 19__
Date completed 7/2/99 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		6

8. **WELL CONSTRUCTION**
Depth Drilled 780 Feet Depth Cased 780 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	780 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1	780

Perforations:
Type perforation MILL SLOT
Size perforation 3/16 X 3
From 680 feet to 700 feet
From 740 feet to 760 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 780 feet

9. **WATER LEVEL**
Static water level 425 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling off-site or contractor)
Date 7/2/99

USE ADDITIONAL SHEETS IF NECESSARY