WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77760
Permit No.
Basin 37

NOTICE OF INTENT NO. 40200

1. OWNER CAROLYN PAISANO
MAILING ADDRESS BOX 95
MOUNTAIN CITY, NV 89831

ADDRESS AT WELL LOCATION 529 DAVIDSON ST.
MOUNTAIN CITY, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 36 T 46N N/S R 53E E ELKO County
PERMIT NO. WELL # MW-4 (Issued by Water Resources) | 003-417-001 (Parcel No.) | TOWN OF MOUNTAIN CITY (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SAND & GRAVEL		2	8	6
SAND		8	15	7
SAND, GRAVEL, &	X	15		
BOULDERS			20	5
7" FLUSH MOUNT WELL VAULT INSTALLED AT SURFACE				

RECEIVED 99 MAR 25 AM 11:56 WATER RESOURCES OFFICE

Date started 2/10/99 , 19__
Date completed 2/10/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1		1

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	PVC	SCH 40	-.25	18

Perforations:
Type perforation MILLSLOT
Size perforation .020
From 3 feet to 18 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 2.5'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 2.5 feet to 18 feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 2/15/99

USE ADDITIONAL SHEETS IF NECESSARY