WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77762
Permit No. 63022
Basin 63

NOTICE OF INTENT NO. [redacted]

1. OWNER MIDAS JOINT VENTURE
MAILING ADDRESS 6151 LAKESIDE DR. #2100
RENO, NV 89511

ADDRESS AT WELL LOCATION KEN SNYDER MINE, MIDAS, NV REPLACEMENT FOR WELL PW-1

2. LOCATION SW 1/4 NE 1/4 Sec. 27 T 39N N/S R 46E E ELKO County
PERMIT NO. 63022 (Issued by Water Resources) | 004-260-003 (Parcel No.) | TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial (Mining) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	60	
GREY & BLACK ROCK	X	60	460	400
BLACK & GREEN ROCK		460	520	60
BLACK & GREEN W/ CLAY	X	520	670	150
GREEN & GREY ROCK	X	670	760	90

RECEIVED 99 MAR 26 AM 11:56 STATE ENGINEER'S OFFICE

Date started 12/29/98, 19__
Date completed 1/2/99, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
EST 100+		16

8. WELL CONSTRUCTION
Depth Drilled 760 Feet Depth Cased 740 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
18	Inches	0	Feet	15	Feet
12 3/4	Inches	15	Feet	760	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14 3/4	28	.250	+1	16
8 5/8	17	.188	+1	740

Perforations:
Type perforation MILLSLOT
Size perforation 1/8 X 3
From 315 feet to 740 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 740 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1/6/99

USE ADDITIONAL SHEETS IF NECESSARY