WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77769
Permit No.
Basin 85

NOTICE OF INTENT NO. 42816

1. OWNER BYRON WHOLEY
MAILING ADDRESS 10270 Crockett Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Louden Ct.
Sparks, Nevada 89436

2. LOCATION NW ¼ NW ¼ Sec. 13 T 21N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 076-360-51 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 1 | 1 |
| Brown clay with decomposed granite | | 1 | 4 | 3 |
| Blow sand & gravels | | 4 | 6 | 2 |
| Decomposed granite | | 6 | 8 | 2 |
| Weathered granite | | 8 | 68 | 60 |
| White granite | | 68 | 81 | 13 |
| Weathered granite | | 81 | 93 | 12 |
| Rusty granite with clay streaks | | 93 | 180 | 87 |
| Hard white granite | | 180 | 315 | 135 |
| Rusty weathered granite | | 315 | 393 | 78 |
| Weathered granite | | 393 | 488 | 95 |
| Fracture granite | X | 488 | 491 | 3 |
| Black volcanic rock | | 491 | 505 | 14 |
| Fracture black rock | X | 505 | 541 | 36 |
| Gray granite | | 541 | 550 | 9 |

Date started Sept. 15, 19 99
Date completed Sept. 20, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 22 | | |

8. WELL CONSTRUCTION
Depth Drilled 550 Feet Depth Cased 550 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 50 Feet |
| 8 5/8 Inches | | 50 Feet | 550 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 0 | 550 |

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 485 feet to 545 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 550 feet

9. WATER LEVEL
Static water level 470 feet below land surface
Artesian flow G.P.M. 22 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date September 23, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627