

OFFICE USE ONLY
Log No. 77770
Permit No. 89
Basin 42817

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42817

1. OWNER DAN KOOZER ADDRESS AT WELL LOCATION 4320 South Jumbo Grade Way
MAILING ADDRESS P.O. Box 781 Carson City, Nevada 89704
2. LOCATION SE 1/4 NW 1/4 Sec. 5 T 18N R 20 E Washoe County New Washoe Valley
PERMIT NO. 050-433-19 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with boulders		0	1	1
Gray to brown volcanic rock		1	4	3
Brown volcanic rock		4	10	6
Multi-color volcanic rock		10	38	28
Brown volcanic rock		38	71	33
Gray volcanic rock		71	110	39
Brown volcanic rock		110	160	50
Rusty soft granite with clay streaks		160	217	57
Weathered granite		217	238	21
Fracture (app 3 GPM)	X	238	239	1
Gray granite		239	260	21
Fracture	X	260	263	3
Gray hard granite		263	278	15
Fracture granite	X	278	311	33
Gray granite		311	325	14

8. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 325 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	325

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 260 feet to 320 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 foot Neat Cement
Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
From 50 feet to 325 feet

Date started Sept. 21, 19 99
Date completed Sept. 23, 19 99

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		

9. WATER LEVEL
Static water level 155 feet below land surface
Artesian flow _____ G.P.M. 25+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Wayne Drilling, Inc.
By Driller performing actual drilling on site or contractor
Date September 23, 1999