WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77781
Permit No.
Basin

NOTICE OF INTENT NO. 36965

1. OWNER Richard L. Bitton
MAILING ADDRESS
ADDRESS AT WELL LOCATION None

2. LOCATION NE ¼ SW ¼ Sec. 19 T. 33 N/S R. 58 E ELKO County
PERMIT NO. 61587 Issued by Water Resources | 003-018-002 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil & hard packed clay		0	4	4
Boulders & cobbles		4	25	21
Coarse clean sand		25	41	16
Loosely cemented coarse sand & gravel		41	119	78
Coarse loose sand	✓	119	120	1
Coarse sand & gravel	✓	120	142	22
Sand, gravel, clay & boulders		142	165	23
Poorly cemented coarse sand	✓	165	197	32
Coarse sand & gravel	✓	197	198	1
Sand, gravel & clay		198	203	5
T.D. 203 ft				

GLACIAL TILL

Date started 7-29, 1999
Date completed 8-10, 1999

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35.	6	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 203 Feet Depth Cased 204 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	119 Feet
8 Inches	119 Feet	203 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	203

Perforations:
Type perforation Torch cut
Size perforation 1/16 x 5"
From feet to feet
From 114 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to Unk. 2 yds feet

9. WATER LEVEL
Static water level 112 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co. (Contractor)
Address 203 Pine St. (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 8-24-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627