WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77783
Permit No.
Basin 48

NOTICE OF INTENT NO. 41828

1. OWNER K.J. & KAY J. BILLINGSLEY
MAILING ADDRESS 210 MODOC DR.
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION NE CORNER OF 3RD & PATTON

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T 32N N/S R 55E E ELKO County
PERMIT NO. _____ Issued by Water Resources
027-032-003 Parcel No.
LUCKY NUGGET #1 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
SILTSTONE & BOULDERS		3	30	27
SILTSTONE & GRAVEL	X	30	140	110

RECEIVED
99 JUN 21 PM 2:59
STATE ENGINEER'S OFFICE

Date started 6/15/99 , 19__
Date completed 6/15/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		3

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	140

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Dennis Hansen (By driller performing actual drilling on-site or contractor)
Date 6/18/99

USE ADDITIONAL SHEETS IF NECESSARY