WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77785
Permit No.
Basin 117

NOTICE OF INTENT NO. 41824

1. OWNER BOB BURROWS
MAILING ADDRESS 428 RIVER ST.
ELKO, NV 89801

ADDRESS AT WELL LOCATION OFF ROAD TO BALD MT. MINE

2. LOCATION SW 1/4 SW 1/4 Sec. 15 T 26N N/S R 56E E ELKO County
PERMIT NO. (Issued by Water Resources) 006-230-002 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
TOPSOIL		0	8	8
CLAY		8	22	14
LARGE GRAVEL	X	22	40	18
GREY/WHITE ROCK W/		40		
BROWN SEAMS			380	340
GREY/WHITE/BROWN	X	380		
ROCK-FRACTURED			440	60

RECEIVED 99 JUN 21 PM 2:58 STATE ENGINEER'S OFFICE

Date started 5/27/99, 19__
Date completed 6/2/99, 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		3.5

8. **WELL CONSTRUCTION**
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	440	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15	.220	+1	420
6 5/8	13	.188	420	440

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 420 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 440 feet

9. **WATER LEVEL**
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO,NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed (By driller performing actual drilling on-site or contractor)
Date 6/4/99

USE ADDITIONAL SHEETS IF NECESSARY