WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77788
Permit No.
Basin 101

NOTICE OF INTENT NO. 39452

1. OWNER JIM HARMON
MAILING ADDRESS 5281 TOYON
FALLON, NV 89406

ADDRESS AT WELL LOCATION 5281 TOYON

2. LOCATION ~~NE~~ NW 1/4 ~~SW~~ SE 1/4 Sec. 22 T 18 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
006-436-34 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BR BR SAND		0	20	
BR CLAY		20	23	3
BR SAND		23	40	17
GREY SAND		40	70	30
BL CLAY		70	80	10
GREEN SAND		80	95	15
GREY SAND		95	115	20
GREY CLAY		115	117	2
BR SAND	X	117	128	11

8. WELL CONSTRUCTION
Depth Drilled 128 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	128	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	128

Perforations:
Type perforation MACHINBE SLOT
Size perforation 3/32
From 122 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 18'7" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

Date started 6/23/1999 , 19__
Date completed 6/23/1999 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 7/12/99

USE ADDITIONAL SHEETS IF NECESSARY