WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77791
Permit No.
Basin 10

NOTICE OF INTENT NO. 36242

1. OWNER JERRY STANTON
MAILING ADDRESS 3360 SILVER STATE BLVD
FALLON,, NV 89406

ADDRESS AT WELL LOCATION 3360 SILVER STATE BLVD

2. LOCATION NW 1/4 NE 1/4 Sec. 27 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
Parcel No. 10-091-13
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BR SAND | | 0 | 5 | |
| BR CLAY | | 5 | 15 | 10 |
| BR CLAY | | 15 | 20 | 5 |
| BR SAND | | 20 | 35 | 15 |
| GREY SAND | | 35 | 50 | 15 |
| GREY CLAY | | 50 | 55 | 5 |
| GREY SAND | | 55 | 65 | 10 |
| BL CLAY | | 65 | 66 | 1 |
| BL SAND | X | 66 | 73 | 7 |

99 JUL 15 AM 10:52

Date started 6/17/1999, 19__
Date completed 6/17/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 1 HR |

8. WELL CONSTRUCTION
Depth Drilled 73 Feet Depth Cased 73 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 1/4 | Inches | 0 | Feet | 50 | Feet |
| 6 1/4 | Inches | 50 | Feet | 73 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.9 | .188 | +2 | 73 |

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32
From 68 feet to 72 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 6'4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 7/12/99

USE ADDITIONAL SHEETS IF NECESSARY