WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77802
Permit No.
Basin 101

NOTICE OF INTENT NO. 39451

1. OWNER CARL NORRIS
MAILING ADDRESS 4040 MARGOREE LANE
FALLON, NV 89406

ADDRESS AT WELL LOCATION RENO HWY

2. LOCATION SE 1/4 NE 1/4 Sec. 28 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. 64466 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BR SAND		0	9	-161
BR CLAY		9	13	4
BR SAND		13	40	27
GREY SANMD		40	50	10
BR SAND		50	70	20
BL SILT&SAND		70	100	30
GREY SAND		100	140	40
GREY SAND& CLAY		140	150	10
GREY SAND		150	160	10
BL SAND	X	160	170	10

RECEIVED
99 MAY 21 AM 10:58
STATE ENGINEER'S OFFICE

Date started 4/19/1999, 19__
Date completed 4/24/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		1 HR

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	100	Feet
6 1/4	Inches	100	Feet	170	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	2	170

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 164 feet to 168 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 23'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed [signature] By driller performing actual drilling on-site or contractor
Date 05/10/99

USE ADDITIONAL SHEETS IF NECESSARY