WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77803
Permit No.
Basin 101

NOTICE OF INTENT NO. 39445

1. OWNER KOPAS KONSTRUCTION
MAILING ADDRESS P. O. BOX 5024
FALLON, NV 89406

ADDRESS AT WELL LOCATION 4070 ALLEN ROAD

2. LOCATION SE 1/4 SE 1/4 Sec. 12 T 18 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
026-331-52 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BR SAND		0	10	
BROWN CLAY		10	15	5
BR SAND		15	25	10
GREY SAND		25	50	25
BLK SILT		50	70	20
GREY CLAY		70	75	5
GREY SAND		75	100	25
GREY CLAY		100	105	5
BROWN SAND	X	105	112	7

Date started , 19
Date completed , 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 112 Feet Depth Cased 112 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	50	Feet
6 1/4	Inches	50	Feet	112	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	112

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32
From 106 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 10'5" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 7/12/99

USE ADDITIONAL SHEETS IF NECESSARY