WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77805
Permit No.
Basin 101

NOTICE OF INTENT NO. 42763

1. OWNER Wayne Hemloth
MAILING ADDRESS 5730 Rivers Edge
ADDRESS AT WELL LOCATION 5730 Rivers Edge

2. LOCATION SE 1/4 NW 1/4 Sec. 29 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 855127 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set up over existing well to reinstall 100 seal overdrilled 10 3/4 washover pipe 10 3/4 & cutters drilled to 100' pulled washovers and installed 1 trimmy pipe to 100' and pumped 7 sack per yard sand grout 2 yds. Then centered hole with 2" jet to clean fill inside casing Tagged welded plate on bottom of 4 1/2 casing				

Date started Aug 3, 1999
Date completed Aug 4, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4	Inches	0 Feet	100 Feet
6 1/8	Inches	100 Feet	172 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.08	+1	168
4 1/2	9	.08	150 1/2	170 1/2

Perforations:
Type perforation Machine cut
Size perforation 48
From 165 1/2 feet to 169 1/2 feet 4 1/2 liner
From feet to feet
From 162 feet to 166 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling (Contractor)
Address 305 E Williams Ave (Contractor)
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the 1996

8-6-99
Jesus Marquez