WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77806
Permit No.
Basin 26

NOTICE OF INTENT NO. 39436

1. OWNER FERNLEY HILLS ENTERPRISE
MAILING ADDRESS P. O. BOX 1259
FERNLEY, NV, NV 89408

ADDRESS AT WELL LOCATION

2. LOCATION NE 1/4 SW 1/4 Sec. 12 T 19 N/S R 25 E LYON County
PERMIT NO. Issued by Water Resources Parcel No. FERNLEY HILLS Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND&BOULDERS		0	25	~~164~~
BROWN CLAY		25	60	35
BROWN SAND, HARD CLAY		60	165	105
BLACK ROCK	X	165	189	24

RECEIVED
99 MAY 21 AM 10:58
STATE ENGINEER'S OFFICE

Date started 4/11/1999 , 19__
Date completed 4/24/1999 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		1 HR

8. WELL CONSTRUCTION
Depth Drilled 189 Feet Depth Cased 189 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	50	Feet
8 3/4	Inches	50	Feet	189	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	189

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 169 feet to 189 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2093
Signed By driller performing actual drilling on-site or contractor
Date 5/19/99

USE ADDITIONAL SHEETS IF NECESSARY