WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 77813
Permit No.
Basin 101

NOTICE OF INTENT NO. 36404

1. OWNER LAHONTAN MANUFACTURED HOMES
MAILING ADDRESS 4700 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1390 RICE ROAD

2. LOCATION SW 1/4 NE 1/4 Sec. 24 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
008 326 31 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	13	13
BROWN CLAY		13	15	2
BROWN SAND		15	30	15
BROWN CLAY		30	32	2
BROWN SILT		32	40	8
GREY SAND		40	60	20
BLACK SILT		60	82	22
GREY CLAY		82	85	3
BROWN SAND		85	95	10
GREY SAND		95	150	55
BLACK SILT		150	170	20
GREY SAND		170	198	28
BROWN CLAY		198	205	7
BROWN SAND	X	205	232	27

Date started 10/13/97 , 19__
Date completed 10/13/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 232 Feet Depth Cased 232 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	232	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	232

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 207 feet to 214 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 35.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Drilling Contractor
Address P.O. Box 888 Contractor
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed
By driller performing actual drilling on-site or contractor
Date

USE ADDITIONAL SHEETS IF NECESSARY