WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77822
Permit No.
Basin 88

NOTICE OF INTENT NO. 42913

1. OWNER Washoe County Utilities
MAILING ADDRESS 4930 Energy Way
Reno, NV. 89502

ADDRESS AT WELL LOCATION Beside Lake Geneva Drive
Reno NV.

2. LOCATION SE ¼ SW ¼ Sec. 3 T. 17 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 148-01-021 (Parcel No.) Montroeaux (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Measured static water level @ 336.4'. Depth of well measured at 609.3'. Installed 605' of 1" tremme pipe. Mixed 34 bags of Portland Type II cement and approx. 200 gallons of water. Pumped cement into well from bottom to surface. Casing was then cut off 1' below ground level. Well should have required approx. 14 cubic feet but actually used 1.25 cu. yds. of neat cement. | | | | |

99 DEC 13 PM 1:56
STATE ENGINEER'S OFFICE

Date started December 7, 1999
Date completed December 7, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 611' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | | sch. 40 | +1 | 611' |

Perforations:
Type perforation slotted
Size perforation n/a
From ____ feet to ____ feet
From 252' feet to 611' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 611'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 336.4' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address 1401 North RoopSt. (Contractor)
Carson City, NV. 89701

Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed Dan Trampe (By driller performing actual drilling on site or contractor)
Date December 10, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627