

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77825
 Permit No. _____
 Basin 89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **40306**

1. OWNER Steep Weiss ADDRESS AT WELL LOCATION 3155 Holly Lane
 MAILING ADDRESS 3155 Holly Lane
Carson City, NV 89704

2. LOCATION NW 1/4 NW 1/4 Sec. 5 T 16 N/S R 20 E Washoe County
 PERMIT NO. 050-450-14 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.G.		0	15	15
Brown sandy clay		15	20	5
Large gravel with brown sandy clay		20	30	10
Weathered granite		30	45	15
Multi colored volcanic rock with weathered granite		45	50	5
Weathered granite with orange		50	60	10
Weathered granite		60	90	30
Fractured weathered granite		90	100	10
Weathered granite hard		100	128	28
Fractured weathered granite		128	135	7
Weathered granite hard		135	145	10
Fractured weathered granite		145	148	3
Weathered granite hard		148	150	2
Fractured weathered granite		150	152	2
Weathered granite hard		152	195	43
Fractured weathered granite		195	200	5
Weathered granite hard		200	263	63
Large orange black white granite chunks		263	275	12
Hard weathered granite		275	305	30
Multi colored gravels		305	325	20
Weathered granite		325	345	20
Multi colored gravels		345	400	55
T.D. 400'				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0	60
7 7/8 Inches	60	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	400

Perforations:
 Type perforation Factory sawed
 Size perforation 3/32x3

From	To
400 feet	360 feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 400 feet to 50 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc Contractor
 Address P.O. Box 60130 Contractor
Reno, Nv 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed [Signature] by driller performing actual drilling on-site or contractor
 Date 8/10/99

Date started 7/26/99, 19____
 Date completed 8/5/99, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20+</u>		<u>2 hours</u>	