WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77826
Permit No.
Basin 85

NOTICE OF INTENT NO. 39808

1. OWNER Carol Thorson
MAILING ADDRESS 2605 Pleasant View Place
Sparks, NV 98434

ADDRESS AT WELL LOCATION 2605 Pleasant View Place
Sparks,Nv 89434

2. LOCATION NW 1/4 NW 1/4 Sec. 1 T 19N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources
030-204-12 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dark Green Rock		245	256	
Green,Brown and Red		256		
Volcanic Rock			282	26
Red Volcanic Rock		282	289	7
Red,Brown and Green		289		
Volcanic Rock			356	67
Yellow and Red	x	356		
Volcanic Rock			389	33
Blue Clay		389	395	6

Date started 9/1/99 , 19__
Date completed 9/4/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	252	1-1/2 hr

8. WELL CONSTRUCTION
Depth Drilled 395 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6-1/8	Inches	245	Feet	395	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	6.96	.188	395	235

Perforations:
Type perforation Factory Sawed
Size perforation 1/8 x 3
From 395 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal In Place
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0035387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Larry Welch (By driller performing actual drilling on-site or contractor)
Date 9/20/99

USE ADDITIONAL SHEETS IF NECESSARY

99 SEP 22 AM 10:57 STATE ENGINEER'S OFFICE