REPORT NO. 99.66

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 17837
PERMIT NO.
BASIN

NOTICE OF INTENT NO. 3169

1. OWNER David Fong
MAILING ADDRESS 815 Mountian Ave. Apt A-3 Springfield,NJ 07081
ADDRESS OF WELL 5010 Fandango Lot 501 Reno, Nv 89511

2. WELL LOCATION SW 1/4 SE 1/4 SEC. 8 T 17 R 21E E Storey COUNTY

PERMIT NO ____ PARCEL NO APN 3-412-06 SUBDIVISION NAME Virginia City Highlands

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Fill dirt rock & clay		0	5	5
Red, yellow rock & clay		5	10	5
Red rock volcanic		10	15	5
Brown & white volcanic		15	25	10
Red clay, Red volcanic		25	35	10
Purple, black,&white rock		35	40	5
Purple & brown clay		40	45	5
Brown, purple & white rock		45	65	20
Green,brown & white hard rock		65	77	12
Red clay, green & red rock		77	90	13
M[illegible] colored volcanic rock		90	150	60
Red volconic rock		150	160	10
Red rock, lite brown clay		160	165	5
Multi volcanic rock		165	195	30
Green gravel	X	195	210	15
Red& Brown clay & rock Green	X	210	220	10
Gravel	X	220	235	15

Notes :

RECEIVED 99 NOV 19 PM 12: 13 STATE ENGINEERS OFFICE

Date Started 11/10/99 Date Completed 11/12/99

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		1

8. WELL CONSTRUCTION

Depth Drilled 235' Depth Cased 235'

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 52 Feet
8 3/4 Inches 52 Feet 65 Feet
8 1/2 Inches 65 Feet 235 Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	235

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 215 Feet to 235 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
SEAL TYPE: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Seal Depth 52'
PLACEMENT METHOD: [ ] Pumped [X] Poured

GRAVEL PACKED: [X] Yes [ ] No
From 52' Feet to 235' Feet

9. WATER LEVEL
Static Water Level 140 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, Nevada 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [signature]
By driller performing actual drilling on site or contractor

Dated November 16, 1999