


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 77851
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19602

1. OWNER Jim Kavacs & Darlene Borgman ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3030 W. Silver Sage 3030 W. Silver Sage
Pahrump, NV 89048

2. LOCATION SE 1/4 SE 1/4 Sec. 24 T 19S N/S R 52E E Nye County
 PERMIT NO. 27-734-21 Mejectic View Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	6	6
grey loam		6	9	3
brown loam		9	17	8
grey loam		17	26	9
See next line	x	26	78	52
light brown loam with caleche strings				
See next line	x	78	94	16
white clay with caleche strings				
See next line	x	94	102	8
grey loam with caleche strings				
brown loam	x	102	122	20
brown clay	x	122	125	3
brown loam	x	125	127	2
grey loam	x	127	140	13

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation sawcut
 Size perforation .188

From 115 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet



Date started 12/16/99 19____
 Date completed 12/16/99 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 1.3.00

