WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77862
Permit No.
Basin 162

NOTICE OF INTENT NO. 19590

1. OWNER CR Homes/Ophif
MAILING ADDRESS 3751 S. Ophir
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 3751 S. Ophir

2. LOCATION NW 1/4 SE 1/4 Sec. 34 T 20S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 40-692-15 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	8	8
See next line		8	18	10
brown clay with caleche strings				
brown caleche		18	48	30
brown clay	x	48	102	54
brown caleche	x	102	106	4
brown clay	x	106	140	34

DCNR/DWR Received JAN 5 2000 LAS VEGAS OFFICE

Date started 10/27/99 , 19__
Date completed 10/27/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation sawcut
Size perforation .188
From 115 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed (By driller performing actual drilling on-site or contractor)
Date 10-30-99