WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77866
Permit No.
Basin 162

NOTICE OF INTENT NO. 19586

1. OWNER AVCO/Adair
MAILING ADDRESS 5520 E. Santovito
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 5520 E. Santovito

2. LOCATION SE 1/4 SE 1/4 Sec. 16 T 21S N/S R 54 E Nye County
PERMIT NO. _____ Issued by Water Resources
43-091-23 Parcel No.
Cottonwoods Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| brown loam and gravel | | 0 | 34 | 34 |
| See next line | | 34 | 87 | 53 |
| brown clay with grey caleche strings | | | | |
| brown clay and rock | x | 87 | 129 | 42 |
| brown clay and gravel | x | 129 | 160 | 31 |

DCNR/DWR Received JAN 5 2000 LAS VEGAS OFFICE

Date started 10/11/99, 19__
Date completed 10/11/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160+1 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 11 Inches | | 0 Feet | 160 Feet |
| _____ Inches | | _____ Feet | _____ Feet |
| _____ Inches | | _____ Feet | _____ Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 3.7 | .280 | 0 | 160 |
| | | | | |

Perforations:
Type perforation sawcut
Size perforation .188
From 135 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed _____ By driller performing actual drilling on-site or contractor
Date 10-30-99