WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77892
Permit No.
Basin 212

NOTICE OF INTENT NO. 19520

1. OWNER CITY OF HENDERSON
MAILING ADDRESS 240 WATER ST
HENDERSON NV 89105

ADDRESS AT WELL LOCATION 390 ATHENS AVE
HENDERSON NV

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 21 (N)S R. 63 E. CLARK County
PERMIT NO. Issued by Water Resources | 160-31-101-001 Parcel No. | Subdivision Name B-3

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SILTY SAND | | 0 | 19 | 19 |
| SAND | | 19 | 21 | 2 |
| SANDY CLAY | | 21 | 60 | 39 |

Date started 8/25, 1999
Date completed 8/25, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 60 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | | SCH. 40 | 0 | 60 |
| | | | | |
| | | | | |

Perforations:
Type perforation SLOTTED
Size perforation 0.020
From 15 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout ☒ BENTONITE
Gravel Packed: ☑ Yes ☐ No
From 15 feet to 60 feet

9. WATER LEVEL
Static water level 18.0' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SPECTRUM EXPLORATION (Contractor)
Address 16662 GEMINI LN (Contractor)
HUNTINGTON BEACH CA 92674
Nevada contractor's license number issued by the State Contractor's Board 34699
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2059
Signed (By driller performing actual drilling on site or contractor)
Date Jan 5/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627