WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 77909
Permit No.
Basin 212

NOTICE OF INTENT NO. 19473

1. OWNER Michael M. Moore
MAILING ADDRESS 8565 Corbett St.
Las Vegas, Nev. 89149

ADDRESS AT WELL LOCATION
BVacant

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 19S N/S R. 60 E. Clark County
PERMIT NO. ____ Issued by Water Resources | Parcel No. 125-19-102-027 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	30	
Cemented Gravel		30	90	
Gravel & Boulders		90	540	
Gravel & Water	xx	540	560	
Boulders		560	660	
Gravel & Water	xx	660	680	
Boulders		680	705	

DCNR/DWR Received JAN 3 2000 LAS VEGAS OFFICE

Date started 11/29/99, 19
Date completed 12/6/99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 705 Feet Depth Cased 705 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	55 Feet
8 3/4 Inches		55 Feet	705 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	SRD 21	PVC	+1	705
8 5/8	16.94	.188	+1 1/2	50

Perforations:
Type perforation Factory
Size perforation 3/16 x Scheen Type
From 655 feet to 695 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 515 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 12-15-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627