

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. **78008**
Permit No. _____
Basin. **230**

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **177805**

1. OWNER Beatty General Improvement ADDRESS AT WELL LOCATION Beatty, NV
MAILING ADDRESS Beatty, NV 89003
2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 16 N/S R. 48 E Southside of Durkin Range Nye County
PERMIT NO. 57857 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	15	15
Clay	1st	15	20	5
Clay		20	25	5
Gravel		25	30	5
Large Gravel	2nd	30	35	5
Clay + Sand		35	35	0
Gravel		35	40	5
Bottom of Hole				40'

8. WELL CONSTRUCTION
Depth Drilled 40' Feet Depth Cased 40' Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 40 Feet
10 5/8 Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/4"</u>	<u>PVC</u>	<u>Schedule 80</u>	<u>0</u>	<u>40</u>

Perforations:
Type perforation Machined
Size perforation 3" x 1/8" every 10"
From 20 feet to 40 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal 16'
Placement Method: Pumped Poured Bentonite Grout 16' - 20'
Gravel Packed: Yes No
From 20 feet to 40' feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality _____

Date started May 28, 1999
Date completed May 29, 1999

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co.
Address HC 149 Box 450
Carapace Valley, NV 89000
Nevada contractor's license number 5376A
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed Dave Row
By driller performing actual drilling on site or contractor
Date May 29 1999 1-600