Duplicate Log

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78018
Permit No.
Basin

NOTICE OF INTENT NO. 17779

1. OWNER Funeral Mountain Ranch
MAILING ADDRESS P.O. Box 10
Amargosa Valley, NV 89020
ADDRESS AT WELL LOCATION Casada Way
Amargosa Valley NV 89020

2. LOCATION SE ¼ SE ¼ Sec. 23 T. 16 N/S R. 48 E. Nye County

PERMIT NO. Issued by Water Resources | Parcel No. 19-031-28 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Fine Sand		2	10	8
Sand & Gravel w/Clay		10	98	88
Cemented Sand & Gravel		98	107	9
Sandy Clay		107	128	21
Loose Sand & Gravel	1st	128	157	29
Large Gravel		157	169	12
Sandy Clay		169	209	40
Sand & Gravel	2nd	209	230	21
Bottom of Well				230'

DCNR/DWR Received JAN 14 2000

Date started April 10, 1999
Date completed April 12, 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 230' Feet Depth Cased 230' Feet

HOLE DIAMETER (BIT SIZE)
10¼ Inches From 0 Feet To 230' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC			0	230
Surface Protective Casing				
6' of 8" Steel		.1808 wall	0	6'

Perforations:
Type perforation Machined
Size perforation 3" x 7/8" every 12"
From 150' feet to 170' feet
From 210' feet to 230' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50' feet to 230' feet

9. WATER LEVEL
Static water level 97 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 70° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HC 69 Box 452 Contractor
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed Dave Bou
By driller performing actual drilling on site or contractor
Date Original 4-28-99 1-6-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627