WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 78032
Permit No.
Basin 212

NOTICE OF INTENT NO. 18591

1. OWNER WOOD BINE SOUTHWEST CORP.
MAILING ADDRESS 101 MONTELAGO BLVD.
HENDERSON, NV 89011

ADDRESS AT WELL LOCATION 101 MONTELAGO BLVD.
HENDERSON, NV 89011

2. LOCATION S ¼ NE ¼ Sec. 22 21 N/S R 63 E CLARK County
PERMIT NO. DW1097 (Issued by Water Resources) 160-22-510-005 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandon well #4 & 5 | | | | |
| Both wells-Pulled casings & drill out gravel & placed 4 yards of 9 sack slurry. | | | | |

DCNR/DWR Received JAN 11 2000 LAS VEGAS OFFICE

Date started 12-7, 19 99
Date completed 12-7, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 27' Feet Depth Cased 27' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 27 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | | sch40 | 0 | 27 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4"x2 1/2"x3 rows
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 27'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 6' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B. Allen Jr. (By driller performing actual drilling on site or contractor)
Date 1-7-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627