WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78055
Permit No.
Basin 212

NOTICE OF INTENT NO. 17689

1. OWNER Terrible Herbst
MAILING ADDRESS 5195 S Las Vegas Blvd Las Vegas NV 89119
ADDRESS AT WELL LOCATION 4895 W Spring MTN

2. LOCATION SW ¼ NW ¼ Sec. 18 T 21 N/S R 61 E Clark County
PERMIT NO. ____ Issued by Water Resources | 162.18.201.001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
A/C Type II		0	1	1
Brown Silty/gravel		1	25	24
Cemented Sand & silt		25	30	5
Light brown Sand		30	42	12
Red clay & gravel	42	42	50	8
Caliche		50	53	3
Light Brow Sand & gravel		53	60	7

3 wells on same site

DONFVOWN Received JAN 19 2000 LAS VEGAS OFFICE

Date started 5/15, 1999
Date completed 5/15, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA	NA	

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)
4 Inches From 0 Feet To 60 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40	0	60

Perforations:
Type perforation .010
Size perforation Machine
From 40 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-38
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 38 feet to 60 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Geotechnical Env. Svcs (Contractor)
Address 7560 W Sahara (Contractor)

Nevada contractor's license number issued by the State Contractor's Board Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-10-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627