WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78069
Permit No.
Basin 212

NOTICE OF INTENT NO. 19657

1. OWNER Clark Co. Sanitation District
MAILING ADDRESS 5857 E. Flamingo Rd
Las Vegas, NV 89122

ADDRESS AT WELL LOCATION: 5857 E. Flamingo Rd
APN#161-22-101-001
Las Vegas, NV

2. LOCATION N1/2 ¼ NW ¼ Sec. 22 T. 21S N/S R. 62 E. CLARK County
PERMIT NO. Issued by Water Resources 161-22-101-001 Parcel No. CENTRAL PLANT BAR SCREEN FAC. Subdivision Name

3. WORK PERFORMED: ☐ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock dewater

WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 10-60' dewater wells | | | | |
| Aluvium | | 0 | 6 | |
| Soupy Clay | | 6 | 28 | |
| Dence grey clay | | 28 | 32 | |
| Soupy clay | | 32 | 41 | |
| Dence grey clay | | 41 | 57 | |
| Soupy clay | | 57 | 60 | |

Date started 11/5 19
Date completed 11/10 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 60' Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 60 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | .250 | 0 | 60 |

Perforations:
Type perforation MACHINE
Size perforation 1/10 of 1"x2 1/2"x32 per ft
From 20 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 60 feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
Signed By driller performing actual drilling on site or contractor
Date

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (10)-627

Western Summit