WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78063
Permit No.
Basin 212

NOTICE OF INTENT NO. 19657

1. OWNER Clark Co. Sanitation District
MAILING ADDRESS 5857 E. Flamingo Rd.
Las Vegas, NV 89122

ADDRESS AT WELL LOCATION 5857 E. Flamingo Rd.
APN#161-22-101-001
Las Vegas, NV

2. LOCATION N1/2 ¼ NW ¼ Sec. 22 T 21S N/S R 62 E CLARK County
PERMIT NO. ____ Issued by Water Resources
161-22-101-001 Parcel No.
CENTRAL PLANT BAR SCREEN FAC. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other: Dewater

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other: Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
10-60' dewater wells				
Aluvium		0	6	
Soupy Clay		6	28	
Dence grey clay		28	32	
Soupy clay		32	41	
Dence grey clay		41	57	
Soupy clay		57	60	

Date started 11/5, 19__
Date completed 11/10, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60' Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	0	60

Perforations:
Type perforation MACHINE
Size perforation 1/10 of 1"x2 1/2"x32 per ft.
From 20 feet to 60 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal:
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 60 feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
Signed ____ By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) Western Summit USE ADDITIONAL SHEETS IF NECESSARY (O)-627