WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79080
Permit No.
Basin 212

NOTICE OF INTENT NO. 19657

1. OWNER Clark Co. Sanitation District
MAILING ADDRESS 5857 E. Flamingo Rd.
Las Vegas, NV 89122

ADDRESS AT WELL LOCATION 5857 E. Flamingo Rd.
APN#161-22-101-001
Las Vegas, NV

2. LOCATION N1/2 ¼ NW ¼ Sec. 22 T. 21S N/S R. 62 E. CLARK County
PERMIT NO. ____ Issued by Water Resources. 161-22-101-001 Parcel No. CENTRAL PLANT BAR SCREEN FAC. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
14-50' dewater wells				
Aluvium		0	8	
Wet Red Sand		8	13	
Soupy clay		13	37	
Dence grey clay		37	41	
Soupy clay		41	44	
Dense grey clay		44	50	

Date started 11/3 1999
Date completed 11/9 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50' Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches	0 Feet	50 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	0	50

Perforations:
Type perforation MACHINE
Size perforation 1/10 of 1"x2 1/2"x32 per ft.
From 10 feet to 50 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 50 feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge:
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number 18916 issued by the State Contractor's Board
Nevada driller's license number 1376 issued by the Division of Water Resources, the on-site driller
Signed ____ By driller performing actual drilling on site or contractor.
Date

(Rev. 7-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-027

Western Summit