WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78114
Permit No.
Basin 105

NOTICE OF INTENT NO. 38073

1. OWNER Ron & Jane Tipton
MAILING ADDRESS 1263 Alicia Cr.
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 160 Hwy 395 N.
Gardnerville,NV 89410

2. LOCATION NW 1/4 NE 1/4 Sec. 5 T 11N N/S R 21E E Douglas County

PERMIT NO. (Issued by Water Resources) | Parcel No. 35-360-07 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	6	6
Brn clay & cobbles		6	18	12
Broken Brn Volcanic rock		18	48	30
Brn sandy clay		48	120	72
Brn volcanic gravels	x	120	180	60
Blue volcanic ash & gravels		180	200	20

Date started 11/05/1999, 19__
Date completed 11/08/1999, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		2 hrs

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	200

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/08/19

USE ADDITIONAL SHEETS IF NECESSARY