

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42123

1. OWNER Jim Garrison ADDRESS AT WELL LOCATION 156 Jolie Way Gardnerville NV  
 MAILING ADDRESS Box 435 Gardnerville NV

2. LOCATION SW 1/4 NE 1/4 Sec 5 T 11 R 21 E Douglas County  
 PERMIT NO. 35-360-080 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material                         | Water Strata | From | To  | Thick-ness |
|----------------------------------|--------------|------|-----|------------|
| Boulders Br. Clay                |              | 0    | 30  | 30         |
| Volcanic Rock Brown Clay         |              | 30   | 140 | 110        |
| Same                             |              | 140  | 160 | 20         |
| Solid Volcanic Rock              |              | 160  | 180 | 20         |
| Volcanic Rock Brown Clay         |              | 180  | 220 | 40         |
| OG Grey Clay                     |              | 220  | 240 | 20         |
| Same                             |              | 240  | 280 | 40         |
| Weathered Granite                |              | 280  | 310 | 30         |
| Semi Hard Granite with fractures | L            | 310  | 390 | 80         |

8. WELL CONSTRUCTION  
 Depth Drilled 390 Feet Depth Cased 390 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 50 Feet  
1 1/4 Inches 0 Feet 50 Feet  
9/8 Inches 50 Feet 390 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u>       |                     | <u>1 1/8</u>            | <u>42</u>   | <u>330</u> |

Perforations:  
 Type perforation Mill Slot  
 Size perforation 2/32  
 From 330 feet to 390 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 390 feet

9. WATER LEVEL  
 Static water level 80' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality VIA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NV Drilling Inc. Contractor  
 Address 75 Lewers Cr. Rd Contractor  
Cohen City, NV 89704  
 Nevada contractor's license number issued by the State Contractor's Board 13697-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8-18-99

Date started 8-12, 1999  
 Date completed 8-17, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

|                 | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|-----------------|-----------|-------------------------------|--------------|
| <u>Air/Lift</u> | <u>30</u> | <u>330</u>                    | <u>2 HRS</u> |