WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78116
Permit No.
Basin 107

NOTICE OF INTENT NO. 40798

1. OWNER George Royce
MAILING ADDRESS 3551 Shadow Lane
Carson City, NV. 89705

ADDRESS AT WELL LOCATION [redacted]
Upper Colony

2. LOCATION NW ¼ SW ¼ Sec 27 T 11 N/S R 23 E Lyon County

PERMIT NO. ____ Issued by Water Resources | 10-341-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
decomposed		1	140	140
granite/Boulders				
Clay seams		140	163	23
granite boulder		163	226	63
Clay		226	236	10
granite boulder		236	249	13
granite		249	260	21

RECEIVED
99 OCT -5 PM 12:37
STATE ENGINEERS OFFICE

Date started 9/10/99, 19
Date completed 9/14/99, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 261 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	1 Feet	260' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	1	260'

Perforations:
Type perforation Machine Rent
Size perforation 3/16 x 4 x 5 rows
From ____ feet to ____ feet
From 220 feet to 240 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal ~~Kelp~~ 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 166' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature C °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name [signature] Contractor
Address PO 599 Contractor
S8 NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 9/16/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627