

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37610

1. OWNER Gene Edward S
 MAILING ADDRESS 3289 PENROD LN. #52
GARDNERVILLE NEV 89410
 ADDRESS AT WELL LOCATION 3291 Reese Ln
GARDNERVILLE NEV 89410
 2. LOCATION SE 1/4 SW 1/4 Sec 18 T 11 N/S R 22 E Douglas County
 PERMIT NO. 37121420
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ALUVIAL Top Soil + Rock</u>		<u>0</u>	<u>40</u>	<u>40</u>
<u>Rock + gravel</u>	<u>Y</u>	<u>40</u>	<u>67</u>	<u>27</u>
<u>yellow clay + small rock</u>		<u>67</u>	<u>100</u>	<u>43</u>
<u>COARSE Sand + gravel</u>	<u>X</u>	<u>110</u>	<u>145</u>	<u>35</u>
<u>Hard brown clay</u>		<u>145</u>	<u>150</u>	<u>5</u>

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
6 Inches 50 Feet 150 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>188</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Factory Saw Slot
 Size perforation 3/32 X 3
 From 110 feet to 150 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 10-23- 1999
 Date completed 11-8- 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5</u>	<u>3 HRS.</u>

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Contractor
 Address P.O. Box 92 Contractor
Smith NEV 89430
 Nevada contractor's license number 32166
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 718
 Division of Water Resources, the on-site driller
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date 11-8-99