

OFFICE USE ONLY
 Log No. 78125
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27996

1. OWNER Keith Hart ADDRESS AT WELL LOCATION 769 Parkman Ct. Gardnerville NV. 89410
 MAILING ADDRESS Gardnerville NV. 89410
 2. LOCATION NE 1/4 NE 1/4 Sec. 36 T. 12 S R. 19 E. Douglas County
 PERMIT NO. 19-446-110 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders and Cobbles		0	39	39
Course Dk Sand and Cobbles		39	67	28
Small Sands (Brown)		67	84	17
Fractured Cobbles		84	96	12
Cobbles and Obsidian Boulders		96	124	28
Fractured Cobbles and Sand Dk Sands		124	150	26

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 150 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>150</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x 3/32
 From 130 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type Neat Cement
 Depth of Seal 100
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 150 feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. 35+ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 11-5 1999
 Date completed 11-9 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35+</u>	<u>20</u>	<u>5 HRS</u>

Name Capital City Well Drilling Contractor
 Address 20 Kilgus Dr Carson City, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/10/99

RECEIVED
 99 NOV 12 AM 9:56
 STATE ENGINEERS OFFICE