

OFFICE USE ONLY  
 Log No. 78131  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 40822

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER SALMON-Graham ADDRESS AT WELL LOCATION Caveletti 980 Caveletti  
 MAILING ADDRESS \_\_\_\_\_ GARDNERVILLE NV  
 2. LOCATION SW 1/2 SW 1/4 Sec. 35 T 12 N/S R. 21 E. Waugler County \_\_\_\_\_  
 PERMIT NO. 35-310-060 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                       | Water Strata | From       | To         | Thickness |
|--------------------------------|--------------|------------|------------|-----------|
| <u>Bedrock / DG</u>            |              | <u>1</u>   | <u>78</u>  |           |
| <u>Granite</u>                 |              | <u>78</u>  | <u>163</u> |           |
| <u>DG</u>                      |              | <u>163</u> | <u>376</u> |           |
| <u>Fractured</u>               |              | <u>376</u> | <u>440</u> |           |
| <u>DG / Decomposed Granite</u> |              |            |            |           |

8. WELL CONSTRUCTION  
 Depth Drilled 440 Feet Depth Cased 440 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 60 Feet  
8 3/4 Inches 60 Feet 440 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>13</u>           | <u>1.88</u>             | <u>1</u>    | <u>20</u>  |
| <u>6 5/8</u>       | <u>3040</u>         | <u>PVC</u>              | <u>20</u>   | <u>440</u> |

Perforations:  
 Type perforation Machin Done  
 Size perforation 3/16 x 6 x 6 # rows  
 From 105 feet to 435 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 9. WATER LEVEL  
 Static water level 321 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.       | Draw Down (Feet Below Static) | Time (Hours)     |
|--------------|-------------------------------|------------------|
| <u>12-15</u> |                               | <u>1 3/4 hrs</u> |

Date started 11/1/99, 19\_\_\_\_  
 Date completed 11/4/99, 19\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Green Drilling Inc Contractor  
 Address PO 599 Contractor  
S.S. NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1874  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 11/15/99

RECEIVED  
 90 DEC 14 AM 11:05  
 STATE ENGINEERS OFFICE