WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78135 (78135)
Permit No. 77530
Basin 105

NOTICE OF INTENT NO. 43059

1. OWNER Roy & Mary Collier
MAILING ADDRESS 2315 Kincaid
Minden NV
ADDRESS AT WELL LOCATION 2315 Kincaid

2. LOCATION SW SE ¼ NW NE ¼ Sec. 11 T. 13 N/S R. 20 E Douglas County
PERMIT NO. 77530 Issued by Water Resources
23-100-400 Parcel No.
Johnson Lane 1320-11-001-020 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Soil		0	3	3
Sand		3	17	14
Boulders		17	22	5
Sand & Gravel		22	82	60
Sandy Clay		82	131	49
Sand & Gravel	✓	131	203	72
Clay		203	222	19
Sandy Clay & Gravel		222	253	31
Med Gravel & Sand	W	253	273	20
Sandy Clay		273	275	2

RECEIVED 99 DEC -8 PM 12:25 STATE ENGINEER'S OFFICE

Date started 11-12, 1999
Date completed 11-18, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	+ 25		2 hrs
		NAD27	
		39.005906°N	
		119.699782°W L.J.	

Changes made by L.J. & T.E.

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	275 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	275

Perforations:
Type perforation Factory Milled
Size perforation 40 x 2 1/6 Rows
From 255 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 119 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddie Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 22613 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-21-99

(Rev. 3-91) Deepened by well log 123110 USE ADDITIONAL SHEETS IF NECESSARY (O)-627