

Log No. 78136  
 Permit No. 105  
 Basin         

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36795

1. OWNER Donald Leucy ADDRESS AT WELL LOCATION 1438 Willow Creek  
 MAILING ADDRESS Box 439 Grandmaville, NV  
Genoa, NV 89411  
 2. LOCATION NE 1/4 SW 1/4 Sec. 34 T. 13 S. R. 20 E. Douglas County  
 PERMIT NO. 23-540-15 Subdivision Name Willow Creek  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Boulders		0	18	18
Sandy Clay		18	66	48
Sandy Clay & Gravel		66	92	26
Large Gravel		92	123	31
Sandy Clay		123	129	6
Gravel		129	158	29
Clay		158	160	2

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 160  
10 7/8 Inches Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>1.88</u>	<u>+2</u>	<u>160</u>

Perforations:  
 Type perforation Factory milled  
 Size perforation 7/8 x 2 1/2 G. Row  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Good

Date started 11-7- 1999  
 Date completed 11-11- 1999

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>+30</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eddco Exploration Inc. Contractor  
 Address 7780 Curraj Rd Contractor  
Fallon, NV 89406  
 Nevada contractor's license number 27673A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1586  
 Division of Water Resources, the on-site driller  
 Signed W. McQuinn  
 By driller performing actual drilling on site or contractor  
 Date 11-12-99

2010-0-0112-25  
 STATE ENGINEERING OFFICE