

OFFICE USE ONLY
 Log No. 78142
 Permit No. 71
 Basin. 71

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37320

1. OWNER Gretchen Van Diest ADDRESS AT WELL LOCATION Block 9 Lot C Harry Street
 MAILING ADDRESS P.O. Box 867 Winn, NV 89445
 2. LOCATION NW 1/4 S12 1/4 Sec 8 T 33 R 38 E Pershing County
 PERMIT NO. Green Acres Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	10	10
Sand + Rock		10	50	40
Clay		50	70	20
Rock + Sand		70	110	40
Clay		110	120	10
Sand + Gravel		120	140	20

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>10</u>	<u>1.33</u>	<u>+1</u>	<u>140</u>

Perforations:
 Type perforation Factoru Lt
 Size perforation 3/32 x 4
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 60
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 60 feet to 140 feet

9. WATER LEVEL
 Static water level 59' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 61 °F Quality Good

Date started Feb 19 1999
 Date completed Feb 23 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling Contractor
 Address 10760 Grass Valley Rd Winn, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board: 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2083
 Signed Chris Anderson
 By driller performing actual drilling on site or contractor
 Date Feb 24 1999