

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27998

1. OWNER Mike Noonan ADDRESS AT WELL LOCATION 120 Rivers Rd Dayton NV
 MAILING ADDRESS 120 Rivers Rd Dayton NV 89403
 2. LOCATION 1/4 NW 1/4 Sec 8 T 16 R 27 E Lyon County
 PERMIT NO. NG NE 019-041-10 Parcel No. 21 Subdivision Name 27

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden Blk Sand</u>		<u>6</u>	<u>4</u>	<u>4</u>
<u>Coarse Dk Sands</u>		<u>4</u>	<u>87</u>	<u>83</u>
<u>Brown Sandy Clay</u>		<u>87</u>	<u>136</u>	<u>49</u>
<u>Fine Gray Sands and Clay</u>		<u>136</u>	<u>157</u>	<u>21</u>
<u>Coarse Dk Sands on Fractures Volcanic Sands</u>	<u>XX</u>	<u>157</u>	<u>180</u>	<u>23</u>

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation M/S slot
 Size perforation 3 x 3/32
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow 90° G.P.M. 30 P.S.I.
 Water temperature Hot °F Quality Good

Date started 10-20, 1999
 Date completed 10-21, 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>25</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Kit Kat Drive Carson City, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Deek
 By driller performing actual drilling on site or contractor
 Date 10-25-99

RECEIVED
 99 OCT 25 PM 12:39
 STATE ENGINEERS OFFICE