

OFFICE USE ONLY
 Log No. 78164 9335
 Permit No. V-07074
 Basin 1700
 -Suzhan 3/12/08
 I

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40006

1. OWNER Cherry Creek Water District ADDRESS AT WELL LOCATION 1/2 mile north of
HC 33, Box 33810 Cherry Creek
Ely, Nevada 89301

2. LOCATION SW 1/4 NE 1/4 Sec. 31 T. 24 N. R. 63 E. White Pine County
 PERMIT NO. V04694-V0933500 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE Domestic Municipal Industrial Irrigation Monitor Test Stock

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium		0	10	10
Altered Quartz Monzonite		10	35	25
Fractured Altered Quartz Monzonite	x	35		
Fractured Altered White Quartz Monzonite	x	90	185	95
Notable Water		155	160	5

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
12 1/2	0	40
10	40	185

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	185

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2"
 From 40 feet to 185 feet 6 rows
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 30 - 40
 Placement Method: Pumped Poured See attached letter

Gravel Packed: Yes No
 From 40 feet to 185 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 10 G.P.M. @ 34'
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Richard Lewis By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date December 2, 1999

Date started October 2, 1999
 Date completed November 20, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1 1/2 H.P. Sub Pump set @ 159 ft.	20	116	4
Air Test	30	146	1

RECEIVED
 99 DEC -9 11:10:48
 STATE ENGINEER'S OFFICE