

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO 40000  
 White River Valley

1. OWNER James Bishop  
 MAILING ADDRESS 208 Heritage Drive  
Ely, Nevada 89301  
 ADDRESS AT WELL LOCATION 6 miles west of highway 6)

2. LOCATION SE 1/4 NE 1/4 Sec 9 T 12 N R 60 E White Pine County  
 PERMIT NO. A.P.N. 11-290-02 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	10	10
Volcanic Boulders		10	20	10
Volcanic Boulders & Clay		20	40	20
Fractured Volcanics	x	40	130	90
Volcanics & Clay		130	150	20
Fractured Volcanics	x	150	180	30
Volcanics With Clay		180		
Seams			203	23

8. WELL CONSTRUCTION  
 Depth Drilled 203 Feet Depth Cased 203 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
14	0	20
10	20	203

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	25.22	.188	0	20
6 5/8	12.92	.188	0	203

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" x 2" 6 ROWS

From 101 feet to 203 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 ft.  Neat Cement  
 Placement Method:  Pumped 100' - 5'  Cement Grout  
 Poured 0' - 20'  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 203 feet

9. WATER LEVEL  
 Static water level 20' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 50 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Arnold D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date September 23, 1999

Date started August 5, 19 99  
 Date completed September 3, 19 99

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>300</u>	<u>160</u>	<u>1</u>

RECEIVED  
 99 SEP 27 PM 1 02  
 STATE ENGINEERS OFFICE