

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10734

1. OWNER Newmont Gold Co ADDRESS AT WELL LOCATION here Tree Tailings Dam  
 MAILING ADDRESS 861 West 6th Street  
Winnemucca NV 89445  
 2. LOCATION SW 1/4 NW 1/4 Sec 23 T 34 S R 42 E Humbolt County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>117</u>	<u>117</u>
<u>#8 Sand 42 Bags</u>		<u>7'</u>	<u>115'</u>	<u>108</u>
<u>Enviroplug Course 4 Bags</u>		<u>2'</u>	<u>7'</u>	<u>5'</u>
<u>Cement 1 Bag</u>		<u>0</u>	<u>2</u>	<u>2</u>

8. WELL CONSTRUCTION  
 Depth Drilled 117 Feet Depth Cased 115 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/2 Inches 0 Feet To 6 1/2 Feet  
6 3/4 Inches 6 1/2 Feet 117 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1/4</u>	<u>+ 3</u>	<u>2</u>
<u>2 1/2</u>	<u>PVC</u>	<u>Sch 80</u>	<u>+ 3</u>	<u>115</u>

Perforations:  
 Type perforation Horz slots  
 Size perforation .020  
 From 115 feet to 115 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 2'  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 7' feet to 115' feet

9. WATER LEVEL  
 Static water level: None feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 10-6-99 19 99  
 Date completed 10-6 19 99

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ekland Drilling Co. Contractor  
 Address P.O. Box 2748 Contractor  
Elko NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1079  
 Signed Bruce Clark  
 By driller performing actual drilling on site or contractor  
 Date 10-6-99