WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78187
Permit No.
Basin 101

NOTICE OF INTENT NO. 29263

1. OWNER ADVANCED SCIENTIFIC
MAILING ADDRESS
ADDRESS AT WELL LOCATION 50 W. WILLIAMS AVE. FALLON NV.

2. LOCATION SW ¼ SW ¼ Sec. 30 T 19 N/S R 29 E CHURCHILL County
PERMIT NO. O/O M/O #762 (Issued by Water Resources) A-B 001-124-02 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE ☒ SPARGE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG CTSP #12

Material	Water Strata	From	To	Thickness
WELL WAS IN GOOD				
CONDITION, PULLED				
COVER, OVERDRILLED	10			
CASING AND PRESSURE				
GROUTED TO SURFACE				

RECEIVED
DEC 23 AM 11:18
ENGINEERING DIVISION

Date started 9/17, 1999
Date completed 9/17, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	20 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	FACTORY	0.20	0	20

Perforations:
Type perforation FACTORY
Size perforation 020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 20 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD ROAD (Contractor)
RENO NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2139
Signed (By driller performing actual drilling on site or contractor)
Date 11/11/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

2" = 11
4" = 6
17

17


CRETE
EWAY
CTMW-1
2 inch
2 inch
CTSP-13
4 inch
CCCMW-1
SIDEWALK
2 inch
CTSP-12
2 inch
CTSP-9
2 inch
CTMW-10
CTMW-9
CTMW-6
4 inch
CTMW-8
CTMW-2
2 inch
TY TELEPHONE
G
SIDEWALK
MONITORING TOWER
UST
4 inch
CCCMW-2
CTSP-11
2 inch
CTSP-7
2 inch
CEMENT SIDEWALK
2 inch
CTMW-3
= 10 feet
LEGEND
BUILDING
GROUNDWATER MONITORING WELL LOCATION
SOIL VAPOR EXTRACTION WELL
SPARGE WELL USED BY SYSTEM
EXISTING SPARGE POINT NOT USED BY SYSTEM
DISSOLVED OXYGEN MONITORING WELLS
CTMW-5
inch
2 inch
CTSP-10
CTMW-4
inch
COUNTY
RECORDS
BUILDING
SIDEW